

## ABSTRACT

The techniques described herein allow a wind turbine generator system to automatically capture voltage waveform data corresponding to a voltage disturbance event. Data corresponding to a period preceding the voltage disturbance event, during the event and a period of time after the event are captured and stored for further analysis. The sampling rate is relatively high compared to the frequency of the power provided by the generators.